SIEMENS

Data sheet

6ES7517-3FP00-0AB0



SIMATIC S7-1500F, CPU 1517F-3 PN/DP, central processing unit with work memory 3 MB for program and 8 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT, 3rd interface: PROFIBUS, 2 ns bit performance, SIMATIC Memory Card required

Figure similar

General information	
Product type designation	CPU 1517F-3 PN/DP
HW functional status	FS11
Firmware version	V3.1
FW update possible	Yes
Product function	
● I&M data	Yes; I&M0 to I&M3
• Isochronous mode	Yes; Distributed and central; with minimum OB 6x cycle of 250 μs (distributed) and 1 ms (central)
SysLog	Yes
Engineering with	
 STEP 7 TIA Portal configurable/integrated from version 	V19 (FW V3.1); V13 Update 3 (FW V1.6) or higher
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	6.1 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	1.55 A
Current consumption, max.	1.9 A
Inrush current, max.	1.9 A; Rated value
l²t	0.4 A ² ·s
Power	
Infeed power to the backplane bus	12 W
Power consumption from the backplane bus (balanced)	30 W
Power loss	
Power loss, typ.	24 W
Memory	
Number of slots for SIMATIC memory card	1

SIMATIC memory card required	Yes
Work memory	
integrated (for program)	3 Mbyte
integrated (for data)	8 Mbyte
Load memory	
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	, .
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	2 ns
for word operations, typ.	3 ns
for fixed point arithmetic, typ.	3 ns
for floating point arithmetic, typ.	12 ns
CPU-blocks	
Number of elements (total)	12 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
 Number range 	1 60 999; subdivided into: number range that can be used by the user: 1
0:	59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	8 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	1 Mbyte
FC	
Number range	0 65 535
• Size, max.	1 Mbyte
ОВ	
• Size, max.	1 Mbyte
 Number of free cycle OBs 	100
 Number of time alarm OBs 	20
 Number of delay alarm OBs 	20
Number of cyclic interrupt OBs	20; with minimum OB 3x cycle of 100 µs
Number of process alarm OBs	50
Number of DPV1 alarm OBs	3
Number of isochronous mode OBs	3
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of startup OBs Number of asynchronous error OBs	
•	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
• Number	Any (only limited by the main memory)
	Any (only limited by the main memory)
Retentivity	Voc
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	768 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 700 KB
	Counters, DDs, and technology data (axes). 100 ND

Extended retentive data area (incl. timers, counters, flags), max.	8 Mbyte; When using PS 6 0W 24/48/60 V DC HF
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
 Retentivity adjustable 	Yes
Retentivity preset	No
Local data	
 per priority class, max. 	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	16 384; max. number of modules / submodules
I/O address area	
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	32 kbyte; Max. 32 KB via X1; max. 8 KB via X2 or X3
— Outputs (volume)	32 kbyte; Max. 32 KB via X1; max. 8 KB via X2 or X3
per CM/CP	,,,
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	- ····,··
Number of subprocess images, max.	32
	32
Hardware configuration	CA. A distributed I/O system is abspectagined not only by the interretion of
Number of distributed IO systems	64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• integrated	1
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
• integrated	2
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be
	inserted in total
Rack	
 Modules per rack, max. 	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	Hardware clock
Type Poolun time	Hardware clock
Backup time Deviction nor day, may	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	40
• Number	16
Clock synchronization	
• supported	Yes
• to DP, master	Yes
• on DP, device	Yes
• in AS, master	Yes
• in AS, device	Yes
on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	2
Number of PROFIBUS interfaces	1
1. Interface	
Interface types	
RJ 45 (Ethernet)	Yes; X1
Number of ports	2
• integrated switch	Yes
g	

Protocolo	
Protocols	Voc. IDu4
IP protocol PROFINITIO Controller	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
 SIMATIC communication 	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Services	
— Isochronous mode	Yes
 Direct data exchange 	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
Prioritized startup	Yes; Max. 32 PROFINET devices
Number of connectable IO Devices, max.	512; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
Number of connectable IO Devices for RT, max.	512
	512
— of which in line, max.	
Number of IO Devices that can be simultaneously activated/deactivated, max.	8; in total across all interfaces
Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
— PROFINET Security Class	1
Update time for IRT	
— for send cycle of 250 μs	250 µs to 4 ms
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s 3 875 μ s)
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 µs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	, iii ii i
Services	
— Isochronous mode	No
— IRT	Yes
— PROFlenergy	
	Yes; per user program
— Shared device	Yes
Number of IO Controllers with shared device, max.	4
activation/deactivation of I-devices	Yes; per user program
Asset management record	Yes; per user program
— PROFINET Security Class	SNMP Configuration and DCP Read Only
2. Interface	
Interface types	
RJ 45 (Ethernet)	Yes; X2
 Number of ports 	1
integrated switch	No
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
- po=	,

Web server	Yes
Media redundancy	No
PROFINET IO Controller	
Services	
— Isochronous mode	No
Direct data exchange	No
— IRT	No
— PROFlenergy	Yes; per user program
Prioritized startup	No
Number of connectable IO Devices, max.	128; In total, up to 1 000 distributed I/O devices can be connected via AS-i,
— Number of connectable to Devices, max.	PROFIBUS or PROFINET
 Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 Number of IO Devices that can be simultaneously 	8; in total across all interfaces
activated/deactivated, max.	
 Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
— PROFINET Security Class	1
Update time for RT	
— for send cycle of 1 ms	1 ms to 512 ms
PROFINET IO Device	
Services	
— Isochronous mode	No
— IRT	No
— PROFlenergy	Yes; per user program
 Prioritized startup 	No
— Shared device	Yes
 Number of IO Controllers with shared device, max. 	4
 activation/deactivation of I-devices 	Yes; per user program
 Asset management record 	Yes; per user program
— PROFINET Security Class	SNMP Configuration and DCP Read Only
3. Interface	
Interface types	
• RS 485	Yes; X3
 Number of ports 	1
Protocols	
PROFIBUS DP master	Yes
PROFIBUS DP device	No
SIMATIC communication	Yes
PROFIBUS DP master	
Number of connections, max.	48; for the integrated PROFIBUS DP interface
• max. number of DP devices	125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
Services	THO I BOO OF THO HIVE
— Equidistance	Yes
Equidistance Isochronous mode	Yes
activation/deactivation of DP devices	Yes
	100
Interface types	
RJ 45 (Ethernet)	Voc
• 100 Mbps	Yes
Autorogotiation	Yes
Autocrossing Autocrossing	Yes
Industrial Ethernet status LED	Yes
RS 485	40 Mb W
Transmission rate, max.	12 Mbit/s
Protocols	
PROFIsafe	Yes; V2.4 / V2.6
PROFIsafe Number of connections	
PROFIsafe	Yes; V2.4 / V2.6 320; via integrated interfaces of the CPU and connected CPs / CMs 10

Number of connections via integrated interfaces	288
Number of connections via integrated interfaces Number of S7 routing paths	64; in total, only 16 S7-Routing connections are supported via PROFIBUS
Redundancy mode	04, in total, only 10 37-100thing connections are supported via 1 100 ib03
H-Sync forwarding	Yes
Media redundancy	165
•	only via 1st interface (V1)
— Media redundancy — MRP	only via 1st interface (X1)
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client
 MRP interconnection, supported 	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
 Switchover time on line break, typ. 	200 ms; For MRP, bumpless for MRPD
Number of stations in the ring, max.	50
SIMATIC communication	
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
S7 routing	Yes
Data record routing	Yes
S7 communication, as server	Yes
S7 communication, as client	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; 128 multicast circuits (of which max. 5 via X1)
DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Veb server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
• web API	
— Number of sessions, max.	200
 number of simultaneous HTTP calls, max. 	4
— HTTP request body, max.	131 072 byte
PPC UA	
Runtime license required	Yes; "Large" license required
OPC UA Client	Yes; Data Access (registered Read/Write), Method Call
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15,
Harris and broad 1 12	Basic256Sha256
User authentication	"anonymous" or by user name & password
Number of connections, max.	40
 Number of nodes of the client interfaces, recommended max. 	5 000
 Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC max. 	300 C_U
 Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
 Number of elements for one call of OPC_UA_MethodGetHandleList, max. 	100
 Number of simultaneous calls of the client instructions for session management, per connection, max. 	1
 Number of simultaneous calls of the client instructions for data access, per connection, max. 	5
 Number of registerable nodes, max. 	5 000

Number of registerable method calls of OPC LIA MethodCall may	100
OPC_UA_MethodCall, max. — Number of inputs/outputs when calling	20
OPC_UA_MethodCall, max.	
OPC UA Server	Yes; Data Access (Read, Write, Subscribe), Method Call, Alarms & Condition (A&C), Custom Address Space
 Application authentication 	Yes
— Security policies	available security policies: None, Basic128Rsa15, Basic256Rsa15,
	Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss
— User authentication	"anonymous" or by user name & password
GDS support (certificate management)	Yes
— Number of sessions, max.	64
Number of accessible variables, max.	200 000
Number of registerable nodes, max.	50 000
Number of subscriptions per session, max.	50
— Sampling interval, min.	10 ms
— Publishing interval, min.	10 ms
Number of server methods, max.	100
Number of inputs/outputs per server method, max.	20
Number of monitored items, recommended max.	10 000; for 1 s sampling interval and 1 s send interval
— Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
 Number of nodes for user-defined server interfaces, max. 	30 000
Alarms and Conditions	Yes
Number of program alarms	400
Number of program alarms Number of alarms for system diagnostics	200
Further protocols	
MODBUS	Yes; MODBUS TCP
Isochronous mode	
Equidistance	Yes
S7 message functions	
Number of login stations for message functions, max	64
Number of login stations for message functions, max.	64 750
number of subscriptions, max.	750
number of subscriptions, max. number of tags/attributes for subscriptions, max.	750 20 000
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms	750 20 000 Yes
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max.	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max.	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block,
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering)	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients)
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control variable	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control variable • Variables	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control • Status/control variable • Variables • Number of variables, max.	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max.	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control Status/control Variables Number of variables, max. — of which status variables, max. — of which control variables, max.	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. Forcing • Forcing	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. Forcing • Forcing • Forcing, variables	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. Forcing • Forcing	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. Forcing • Forcing • Forcing, variables	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. Forcing • Forcing • Forcing • Forcing, variables, max. • Number of variables, max.	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
number of subscriptions, max. number of tags/attributes for subscriptions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Profiling Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing Forcing Forcing Forcing Forcing, variables, max. Number of variables, max.	750 20 000 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 10 000 2 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 No Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe) 200

Stable at 150 C	4.000
— of which powerfail-proof Traces	1 000
Number of configurable Traces	8
-	512 kbyte
Memory size per trace, max. Interrupts/diagnostics/status information	312 kbyte
Diagnostics indication LED	Yes
RUN/STOP LED FREDOR LED	Yes
ERROR LED MAINT LED	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	165
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC
Wotton Control	program; selection guide via the TIA Selection Tool
 Number of available Motion Control resources for technology objects 	10 240
 Required Motion Control resources 	
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
 Positioning axis 	
 Number of positioning axes at motion control cycle of 4 ms (typical value) 	70
Number of positioning axes at motion control cycle of 8 ms (typical value)	128
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Highest safety class achievable in safety mode	
Performance level according to ISO 13849-1	PLe
• SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repair time	·
 Low demand mode: PFDavg in accordance with SIL3 	< 2.00E-05
High demand/continuous mode: PFH in accordance with SIL3	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	0 °C
horizontal installation, max.	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
vertical installation, min.	0 °C
vertical installation, max.	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
● max.	70 °C
Altitude during operation relating to sea level	
Installation altitude above sea level, max.	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes; incl. failsafe
— FBD	Yes; incl. failsafe
— STL	Yes
— SCL	Yes

— CFC	Yes; either CFC or failsafe functionality
— GRAPH	Yes
Know-how protection	
User program protection/password protection	Yes
Copy protection	Yes
Block protection	Yes
Access protection	
 protection of confidential configuration data 	Yes
 Password for display 	Yes
 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
 Protection level: Write protection for Failsafe 	Yes
 Protection level: Complete protection 	Yes
User administration	Yes; device-wide
programming / cycle time monitoring / header	
• lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	175 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	1 929 g

last modified:

7/13/2024